



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

555 E. 15th Street
72701-0000, AR Fayetteville
Phone: 479-443-4948
Fax: 479-443-6465



ICS731 1 to 1 Ins Splice

Abb Installation Products, Inc

| | |
|------------------|---|
| Catalog Number | ICS731 |
| Manufacturer | Abb Installation Products, Inc |
| Description | Insulated Aluminum Service Entrance Compression Splice, #2 Awg (Acsr);#1 and #2 Awg (Stranded) Conductor Size, Red Insulation Color, 2 Conductors, 2-25/32 In Overall Length, Compression/Crimp Terminal, 600 V, 0.05 LB/Ea |
| Weight per unit | 0.0450 (lbs/each) |
| Product Category | Large Terminals & Connectors |

Features

| | |
|----------------------|-------------|
| connection | Compression |
| insulation | Yes |
| Material | Aluminum |
| Number of Conductors | 2 |

Dimensions and Weight

| | |
|------|--------------|
| Size | 2-25/32 inch |
|------|--------------|

Descriptions

| | |
|------------------------|-------------------------------------|
| Description | 1 TO 1 INS SPLICE |
| extra long description | ABB ICS73-1 AL SERV ENTR SPLICE A/B |

Manufacturer Information

| | |
|-------|----------------------|
| Brand | Blackburn Mechanical |
| GTIN | 00783786102457 |
| UPC | 783786102457 |

Taxonomies, Classifications, and Categories

| | |
|----------------------|-------------------------------------|
| Category Description | Comp & Mech Lugs and Butt Splices |
| Type | Compression Splice Service Entrance |

Packaging

| | |
|-----------------|-------|
| Carton | 100 |
| Package | 500 |
| Weight Per each | 0.045 |



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

555 E. 15th Street
72701-0000, AR Fayetteville
Phone: 479-443-4948
Fax: 479-443-6465

Uses, Certifications, and Standards

| | |
|--------------------------|---|
| Application | For Standard Conductor Splice |
| environmental conditions | All Seasons / Conditions |
| Mounting | None |
| standard | RUS Accepted. Complies with ANSI C119.4 when properly installed on Aluminum-to-Aluminum or Aluminum-to-Copper Conductors / RUS Accepted. Complies with ANSI C119.4 when properly installed on Aluminum-to-Aluminum or Aluminum-to-Copper Conductors |