

## ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685



### **REA23 1X3/4 Reducer** *Crouse-Hinds*

Crouse-Hinds		
Catalog Number	REA23	
Manufacturer	Crouse-Hinds	
Description	Eaton Crouse-Hinds Series Rea Adapter, Rigid/Imc, End 1: 3/4" NPT, End 2: 1" NPT, Gender End 1: Male, Gender End 2: Female, Steel	
Weight per unit	0.2700 (lbs/each)	
Product Category	Rigid Conduit Fittings - Steel	
Features		
connection	Male Threaded, Female Threaded	
dimensions	1.4400 IN X 1.4400 IN X 1.9500 IN	
Descriptions		
Description	1X3/4 REDUCER	
extra long description	CRS-H REA23 3/4 MALE 1 FEMALE REDUC	
Features	Crouse-Hinds series RE, REA and REC explosionproof reducers are used in rigid/IMC conduit systems to reduce conduit hubs to a smaller size (RE), connect two different sizes of conduit together (REC), or enlarge drilled and tapped openings by one NPT size (REA). PLG explosionproof plugs are used for closing threaded conduit hubs.	
Long Description	Eaton Crouse-Hinds series REA adapter, Rigid/IMC, End 1: 3/4" NPT, End 2: 1" NPT, Gender end 1: male, Gender end 2: female, Steel	
Product Type	3/4 Male 1 Female Reducing Adpt	
Manufacturer Information		
Brand	EATON CROUSE-HINDS SERIES	
GTIN	00782274746470	
Manufacturers Part Number	REA23	
UPC	782274746470	
Taxonomies, Classifications, and C	categories	
Category Description	Locknuts, Bushings, Re-Bushings, Re-Washers, Threaded Plugs, Knockout Plugs	

#### **Packaging**

Type

· · J · J		
Carton	1	
Package	10	
Weight Per each	0.27	

ADAPTER

# ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685

#### **Uses, Certifications, and Standards**

Application	Ind Facilities & Factories - Industrial Facilities/Factories - Other	
Enclosure	Class I Div 1 2 Group A B, Class II Div 1 Group E F G, Class II Div 2	
	Group F G, Class III	
standard	UL 886, CSA C22.2	