



Catalog Number: U5136-O-200S  
Item Description: 200A RL MTR DB PED  
UPC Code: 784572275904

Brand Name: Milbank

Type: Ringless Metered Power Supply Unit

Special Features: 4 Terminal, Plain Top, Ground Bar, Horn Bypass, Single Power Head, 4 Branch Circuits,

Application: Mobile Home Power

Standard: UL Listed

Voltage Rating: Up to 240 Volts Alternating Current

Amperage Rating: 200 Ampere Continuous

Wattage: Not Applicable

Frequency Rating: 60 Hertz

Phase: 1 Phase

Number of Receptacles: 0

Control: One 200 Ampere Main Breaker

Material: G90 Galvanized Steel with Powder Coat Finish

Mounting: Pedestal Mount

Cable Size: 6 AWG to 350 KCMIL

Enclosure: Type 3R



Additional Specifications: Number of Main Breakers:1  
Main Breaker Size:200 Ampere Main Breaker

*Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.*



Catalog Number: U5136-O-200S  
Item Description: 200A RL MTR DB PED  
UPC Code: 784572275904

Brand Name: Milbank

Type: Ringless Metered Power Supply Unit

Special Features: 4 Terminal, Plain Top, Ground Bar, Horn Bypass, Single Power Head, 4 Branch Circuits,

Application: Mobile Home Power

Standard: UL Listed

Voltage Rating: Up to 240 Volts Alternating Current

Amperage Rating: 200 Ampere Continuous

Wattage: Not Applicable

Frequency Rating: 60 Hertz

Phase: 1 Phase

Number of Receptacles: 0

Control: One 200 Ampere Main Breaker

Material: G90 Galvanized Steel with Powder Coat Finish

Mounting: Pedestal Mount

Cable Size: 6 AWG to 350 KCMIL

Enclosure: Type 3R



Additional Specifications: Number of Main Breakers:1  
Main Breaker Size:200 Ampere Main Breaker

*Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.*